


Airtightness checking

GSP-0114-E/B

To measure leaks on DAGARD components assembled according to different configurations encountered in a controlled dust atmosphere.

Principle

The partition to be tested is placed between 2 airtight chambers and subjected to a pressure difference of 50 Pa *0.0072 PSI* (normal use) then 200 Pa *0.029 PSI* (accidental), then 50 Pa *0.0072 PSI* again. The leaks are measured with stabilization at each stage of the test.



Results

Partition tested	Maximum leak at pressure of 50 Pa <i>0.0072 PSI</i>	
	On the partition	Per meter of sealant
walls and ceiling with and without glazing	0,0021 m ³ /h.m ² <i>0.0069 ft³/h/ft²</i>	0,0027 m ³ /h.m <i>0.0088 ft³/h/ft</i>

The airtightness was not altered by a pressure difference of 200 Pa *0.029 PSI*.

Conclusion

Partition and ceiling leak or loss rates are particularly low.

All the products are capable of withstanding significant pressures (200 Pa *0.029 PSI*) without any consequences on tightness quality.

Dagard products meet the required tightness conditions of Controlled atmosphere Enclosures.

Test performed by CETIAT (Technical Centre for Aeraulic and Thermal industries) CR N° 869092